वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 09/11/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | CO 25 | OLR acted | Reset | 17:20:00 | 17:30:00 | |
| 2 | OHP | BRC on CO 28 LT | Field bus fault in drive | Reset | 15:00:00 | 15:25:00 | |
| 3 | OHP | CO 26 | OLR acted | Reset | 17:50:00 | 20:00:00 | 2 times |
| 4 | OHP | CO 50 | OLR acted | Reset | 20:25:00 | 20:35:00 | |
| 5 | CHP | SCR 7 on CC 40 B/C | Modem OK PLc not communicating | PlC power Recycled | 14:30:00 | 15:00:00 | |
| 6 | CHP | CC 36 | B/s Switch Problem | Bypassed | 17:40:00 | 17:50:00 | |
| 7 | CHP | CC 131 | OLR acted | Reset | 19:45:00 | 19:50:00 | |
| 8 | WT | OP9 | OT5 Control MCb trip | Made it on | 16:45:00 | 16:50:00 | |