



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/07/2026

Area: CHP

Equipment	Job
CC-112,111,31,32,33,40,105,104,43,45,125,107	Readings noted
CM-18 LIGHTING	One 200W LED and 35W 3no's installed
CC-107 H/E	200W LED and 35W LED 3no's installed
LIGHTING	CC-38 T/E, Repair Bay backside lighting improved
STK-2	Machine shifting done from CC-106 to CC-35
CC-36,STK-1,CC-213,SCR-9	PPM work done
CC-25,26,27	Slope Area 350w 3no's lights arranged and 35m cable laid
CC-25,26,27 T/E	Area lighting work done. 7no's 75w LED lights installed and 60m cable laid
CC-131,113A,113	Chute sensor modules and CJB's covered properly with sheets
CC-54,CC-132 GALLERY	50W LED Lights 4no's installed
CC-52	Power cable changed to CCR side Drive for Mechanical purpose and again changed to OCR side drive
RG-Building,JH-7	BRS, ZSS, Chute Sensor modules and sensors cleaning done