



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/07/2026

Shift: A

Incharge(s): Nagendra Midde,P Venkat Kiran,P Venkat Kiran

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	olr acted	reset done	07:45:00	07:50:00	
2	CHP	Scr 6 on CC 38	Luff up limit acted	Released	06:25:00	06:35:00	
3	CHP	CC 31	Olr acted	Reset	07:25:00	07:35:00	
4	CHP	Scr 2 on CC 33 Slew	Coal Jamming	Informed to oprn	10:10:00	10:25:00	
5	CHP	R1 on CC 104	B/c Signal Missing	Lt done then ok	11:40:00	11:55:00	