



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/05/2026

Area: WT

Equipment	Job
OP 1	Trolley line cable identified and removed both ends col no 35 and 42
OP 1	Panel and Motor side ppm done
OP 1	Roof cleaning and painting to Mast done
OP 5	Roof painting (red oxide) done
OT 3	Power and Encoder terminations checked and blowing done
CP 2	D4 motor slip rings cleaning and done 3 nos brushes replaced