



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/07/2026

Area: CHP

Equipment	Job
CC 21 carriage drive	Motor removed for overhauling, under progress
CC 26	MCCB incoming jumpers replaced
CC 56/115 gallery	Out side yard focusing 3 nos 350W LED fixtures provided
CC 58	Local PB station replaced
CC 43,45,47,50	PPM was done
CC 50	Motor replaced .Removed motor sent for overhauling
CC 26,26A,TTs, 54	PPM was done