



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/07/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-36	olr acted	RESET DONE	07:20:00	07:30:00	
2	OHP	CO-26	OLR ACTED	RESET DONE	08:35:00	08:45:00	
3	OHP	WOBR -29	LUFFING OLR ACTED	RESET DONE	11:30:00	11:40:00	
4	CHP	CC-21 (C)DRIVE	OLR ACTED	RESET DONE	11:30:00	11:35:00	
5	CHP	CC-107	OLR ACTED	RESET DONE	08:35:00	08:40:00	
6	CHP	CC-33 SCR-2	REPORTED LT NOT TAKING PLACE PCRD DRUM SENSOR ACTED	RELEASED THAN OK	09:20:00	09:36:00	
7	CHP	CC-131	OLR ACTED	RESET DONE	13:20:00	13:25:00	
8	WT	CO-3	OLR ACTED (3 TIMES)	RESET DONE	07:30:00	07:50:00	