



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/05/2026

Area: OHP

Equipment	Job
co-28,27a,30a	motor side ppm is done
wobr-3 on repair bay	All motors canopy is checked, lighting improved near MCC, right Slew limits welding was done in position. shifted from repair bay to co-29, slew cable observed problem, reference changed in drive to keypad mode.
co-2a,rsco-10a ,co-3a,tt-4	motor and panel side ppm is done.
1-14lc3 ; tis-1,2,3 ;	panels and mcc room housekeeping is done.
vf-8a,9a,10a ; co-15a,41a, vf-15a,16a,42a,43a ; cr-1a ; bpc-2, rco-2a	motor and panel side ppm is done.
brc-1 on co-28	bridge conveyor zss arrangement is being done.