



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/08/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	00:30:00	00:40:00	
2	OHP	CO-25	OLR ACTED	RESET DONE	01:45:00	01:55:00	
3	CHP	CC-54	OLR ACTED	RESET DONE	01:00:00	01:10:00	
4	IOSA	OC-33A	OLR ACTED	RESET DONE	03:10:00	03:20:00	