



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/08/2026

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 6A	BW AND SLEW ARE NOT TAKING PLACE/CP 2 ACTING	INFORM TO OPE. AND MECH.	10:50:00	11:10:00	
2	OHP	co 26	tripped on olr	reset done	08:55:00	09:05:00	
3	CHP	CC 203	REPORTED RED/CONTROL MCB TRIPPED	MCB MADE ON	10:30:00	10:40:00	
4	CHP	CC 28	TRIPPED ON OLR	RESET DONE	12:30:00	12:40:00	
5	CHP	CC 52	MPD TRIPPED ON OLR	RESET DONE	10:45:00	10:55:00	
6	CHP	scr 1 on cc31	drive tripped on olr	reset done	09:10:00	09:25:00	
7	CHP	R1 ON CC	BC NOT WORKING	FAULT RESET DONE	10:25:00	10:45:00	
8	CHP	SCR 5 ON CC 39	L NOT TAKING PLACE/PCRD TENSION ACTED	RELEASED	11:10:00	11:25:00	
9	CHP	SCR 9 ON CC 104	LT NOT TAKING PLACE/M6 CONTROL WIRES LOOSE	CONTROL WIRES TIGHTEND	11:20:00	11:35:00	
10	CHP	CC 31	TRIPPED ON OLR	RESET DONE	12:15:00	12:30:00	
11	CHP	SCR 1 ON CC31	SLEW NOT TAKING PLACE/30DEGREE LIMIT ACTED	RELEASED	13:10:00	13:25:00	
12	CHP	R1 ON CC39	BC STOPPING ON ZSS/CAGE STUCKUP	CAGE MADE FREE	10:25:00	10:45:00	