



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/08/2026

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	17:40:00	17:45:00	
2	OHP	VS-4A	OLR ACTED	RESET DONE	15:05:00	15:15:00	
3	OHP	CO-58	REPORTED NOT HEALTHY FOUND CONTROL MCB TRIP DUE TO EARTH FAULT IN PULL CHORD	FIELD WIRES REMOVED AND PC BY PASSED	19:45:00	19:55:00	
4	CHP	CC-111 SCR-3	B/C NOT RUNNING MPD TRIP	RESET DONE	14:45:00	15:00:00	