



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/06/2026

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-29	LUFFING OLR ACTED	RESET DONE	14:10:00	14:20:00	
2	OHP	BRC ON CO-30	REPORTED B/W -1 NOT RUNNING FOUND WIRE LOOSE AT OLR	PROPERLY FIXED THAN OK	20:30:00	21:00:00	
3	OHP	CO-53	CONTROL MCB FAILD	MCB REPLACED THAN OK	20:30:00	21:00:00	
4	CHP	CC-58	OLR ACTED	RESET DONE	17:30:00	17:40:00	
5	CHP	CC-51	MPD TRIP	RESET DONE	16:50:00 17:00:00	16:55:00 17:05:00	
6	CHP	S2 ON CC 39 B/C	ZSS CAGE PIN LOOSE	PROPERLY FIXED	14:20:00	14:30:00	
7	CHP	CC 43	OLR ACTED	RESET	16:45:00	16:50:00	
8	CHP	CC-52	MPD TRIP (2TIMES)	RESET DONE	16:40:00	16:45:00	
9	CHP	SCR 9 ON CC 106	B/C	OPERATOR FAULT	20:50:00	21:00:00	