



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/05/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment                                 | Problem              | Action            | From                 | To                   | Remarks |
|-------|------|-------------------------------------------|----------------------|-------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 26                                     | OLR ACTED            | RESET             | 00:00:00<br>01:20:00 | 00:10:00<br>01:30:00 |         |
| 2     | CHP  | SCR 1 ON<br>CC 31 LUFF                    | OLR ACTED            | RESET             | 23:15:00             | 23:30:00             |         |
| 3     | CHP  | SCR 6 ON<br>CC 104 NO<br>DRIVE<br>RUNNING | RIO CONTROL MCB TRIP | MADE IT ON        | 02:35:00             | 02:55:00             |         |
| 4     | CHP  | CC 131                                    | OLR ACTED            | RESET             | 00:05:00             | 00:10:00             |         |
| 5     | CHP  | CC 54                                     | OLR ACTED            | RESET             | 01:55:00             | 02:00:00             |         |
| 6     | WT   | OT3                                       | D2 TRIP              | RESET             | 23:05:00             | 23:15:00             |         |
| 7     | WT   | CT2<br>REVERSE                            | JAMMING NEAR WHEELS  | AFTER CLEANING OK | 03:10:00             | 03:20:00             |         |