



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/04/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment         | Problem                    | Action           | From     | To       | Remarks |
|-------|------|-------------------|----------------------------|------------------|----------|----------|---------|
| 1     | OHP  | CC 26             | OLR ACTED                  | RESET            | 03:45:00 | 04:50:00 | 4 TIMES |
| 2     | OHP  | WBR ON CO 6A      | BREAKER TRIPPED            | MADE IT ON       | 05:35:00 | 05:45:00 |         |
| 3     | OHP  | TBS ON CO 5A      | B/C FLUID COUPLING OIL LOW | INFORMED TO MECH | 02:30:00 | 02:45:00 |         |
| 4     | CHP  | CC 58             | OLR ACTED                  | RESET            | 05:30:00 | 05:45:00 |         |
| 5     | CHP  | CC 51A RED        | P/C ACTED                  | RELEASED         | 22:35:00 | 22:45:00 |         |
| 6     | CHP  | CC 203            | OLR ACTED                  | RESET            | 22:25:00 | 22:35:00 |         |
| 7     | CHP  | SCR 5 ON CC 33 LT | DRIVE TRIP                 | RESET            | 23:05:00 | 23:15:00 |         |
| 8     | CHP  | SCR 6 ON CC 106   | POWER TRIPPED IN LC 2      | MADE IT ON       | 03:25:00 | 03:40:00 |         |
| 9     | CHP  | CC 107            | OLR ACTED                  | RESET            | 03:40:00 | 03:45:00 |         |