



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/08/2026

Area: CHP

Equipment	Job
CC 130	Motor replaced,alignment done and direction tested.Empty motor currents and vibration readings noted
CC 27A	Motor replaced and trail run was taken.Current and vibration readings noted
R 1	Machine lighting improved after providing 12 nos 35W LED fixtures
SCR 8	Position and stacking angle limits provide with magnetic switches in place of rotary switch,cables laid and tested
CC 45	PPM was done
LC 2	Rooms cleaning done