



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/08/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 29	LT NOT TAKING PLACE/M3 OLR ACTED	RESET DONE	22:35:00	22:50:00	
2	OHP	CO 25	TRIPPED ON OLR	RESET DONE	00:00:00	00:10:00	
3	CHP	CC 38	REPORTED RED/CONTROL MCB TRIPPED	MCB MADE ON	23:05:00	23:10:00	
4	CHP	SCR 5 ON CC32	BC NOT RUNNING/MPD TRIPPED ON OLR	RESET DONE	02:48:00	02:08:00	
5	CHP	CO 26	TRIPPED ON OLR	RESET DONE	01:45:00 03:00:00	01:55:00 03:10:00	
6	CHP	CC 201	TRIPPED ON OLR	RESET DONE	01:30:00	01:35:00	