



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/07/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 102	TT POSITION ON CC106 REQUEST	BYPASSED AT I/O RACK	06:35:00	06:40:00	
2	CHP	CC 52	MPD TRIPPED ON OLR	RESET DONE	12:45:00 13:00:00	12:55:00 13:10:00	
3	CHP	CC51	MPD TRIPPED ON OLR	RESET DONE	12:40:00	12:50:00	
4	CHP	SCR 3 ON CC37	LT NOT WORKING/PCRD CABLE TENSION ACTED	RESET DONE	08:25:00	08:35:00	
5	CHP	CC 131	TRIPPED ON OLR	RESET DONE	13:20:00	13:30:00	