



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/08/2026

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem                                         | Action        | From     | To       | Remarks |
|-------|------|-----------|-------------------------------------------------|---------------|----------|----------|---------|
| 1     | OHP  | CO-10A    | OLR ACTED                                       | RESET DONE    | 05:05:00 | 05:10:00 |         |
| 2     | WT   | OC-1A     | REPORTED NOT HEALTHY FOUND K-2 RELAY LOOP LOOSE | TITED THAN OK | 04:50:00 | 05:05:00 |         |