



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/08/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	23:05:00	23:15:00	3 times
2	OHP	co 26	olr acted	reset	04:20:00	04:30:00	
3	CHP	CC 40	TRIPPED ON OLR440	RESET DONE	04:40:00	04:50:00	
4	CHP	WOBR ON CO 29	BC NOT running,found belt is slipping	informed mechanical	03:25:00	03:35:00	
5	CHP	cc 52	mpd acted	reset	04:45:00	04:50:00	
6	CHP	cc 54	olr acted	reset	05:15:00	05:20:00	
7	WT	OP 10	F/R NOT TAKING PLACE/DID" NT FOUND ANY PROBLEM	RESET DONE IN SYSTEM	22:50:00	23:00:00	