



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/08/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28	BC NOT WORKING/OLR ACTED	RESET DONE	09:40:00	09:50:00	
2	OHP	CO 44	C/S NOT WORKING/	INFORM TO INSTRUMENTATION	12:15:00	12:30:00	
3	OHP	VF 10A	CHUTE VIBRATOR NOT WORKING	MPCB PROBLEM/ INFORM TO G SHIFT	07:40:00	07:50:00	
4	CHP	CC 112	BRS ACTING/	BYPASSED FOR OPERATION REQUIRED	07:05:00	07:15:00	
5	CHP	SCR 7 ON CC40	BC NOT RUNNING/MATERIAL SELECTION PROBLEM	SELECTION DONE	08:05:00	08:20:00	
6	CHP	S1 ON CC36	LT NOT TAKING PLACE/TENSION ACTED DUE TO GUIDE PROBLEM	TENSION RELEASED	08:45:00	09:00:00	
7	CHP	CC 54	TRIPPED ON OLR/5TIMES	RESET DONE	08:00:00	13:20:00	
8	CHP	CC 26	FLAP GATETE TRIPPED ON OLR	RESET DONE	06:30:00	06:40:00	