



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/08/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	TRIPPED ON OLR	RESET DONE	23:50:00	00:00:00	
2	OHP	CO-26	TRIPPED ON OLR FOUR TIMES	RESET DONE	23:52:00	04:05:00	
3	OHP	BRC ON CO-28	BC TRIPPED ON OLR	RESET DONE	05:30:00	05:45:00	
4	CHP	scr-8 CC-112	SLEW NOT WORKING ... OIL LEVEL LOW	INFORMED MECH	22:25:00	22:30:00	
5	CHP	CC-35 S2	BC TRIPPED ON UBC FAULT	RESET AND TESTED	23:15:00	23:25:00	
6	CHP	SCR-2 CC-33	LT NOT WORKING ... PCRD FAST ACTED	RESET DONE	00:30:00	00:40:00	
7	CHP	SCR-7 CC-40	BC TRIPPED ON OLR	RESET DONE	03:30:00	03:40:00	
8	CHP	BRC ON CO-28	BW 2 NOT RUNNING .. FLUID COUPLING PROBLEM	INFORMED MECH	02:20:00	02:30:00	