



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/07/2026

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 25	LT NOT TAKING PLACE/PCRD TENSION ACTED	PCRD TENSION RELEASED 2 TIMES	14:45:00 15:25:00	15:00:00 15:30:00	MOTOR TO DRUM CHAIN PROBLEM
2	OHP	VF 19	MPCB TRIPPED	MADE ON	15:20:00	15:30:00	
3	OHP	TBS ON CO 20	LT NOT TAKING PLACE/PCRD TENSION ACTED DUE TO CABLE ENTANGLED	CABLE WINDING DONE ALONG WITH MECH.	18:30:00	20:10:00	
4	OHP	WOBR ON CO 6A	SLEW ING NOT TAKING PLACE/OIL LEVEL LOW	INFORMED TO OPERATION	21:10:00	21:20:00	
5	CHP	SCR 3 ON CC37	BC NOT RUNNING/MPD TRIPPED ON OLR	RESET DONE	16:05:00	16:15:00	
6	CHP	CC 107	TRIPPED ON OLR	RESET DONE	19:15:00	19:20:00	
7	CHP	CC 131	MPD TRIPPED ON OLR	RESET DONE	17:25:00	17:30:00	
8	CHP	CC58	TRIPPED ON OLR	RESET DONE	21:50:00	22:00:00	