



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/07/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 31	ZSS ACTING/	PROBE AND MODULE REPLACED	20:30:00	21:00:00	NO DELAY
2	OHP	WOBR ON CO 29	LT NOT TAKING PLACE/CONTROL MCB TRIPED	MCB MADE ON	16:20:00	16:25:00	
3	CHP	SCR 7 ON CC40	BC NOT RUNNING/30 DEGREE LIMIT ACTED DUE TO CABLE GOT CUT NEAR MAGNET	RE JOINT DONE	14:15:00	14:50:00	
4	CHP	SCR 1 ON CC 31	BC NOT RUNNING/30DEGREE LIMIT ACTED	RESET DONE	14:35:00	14:50:00	
5	CHP	SCR 2 ON CC32	SLEW NOT TAKING PLACE/JAMMING	INFORM TO OPERATION	15:50:00	16:00:00	
6	CHP	SCR 6 ON CC 38	LT NOT TAKING PLACE/IN LOCAL MODE	KEPT IN REMOTE MODE	20:05:00	20:10:00	
7	CHP	CC 215	ZSS ACTING/DIDNT FOUND ANY PROBLEM	CLEARANCE	21:30:00	21:40:00	
8	CHP	CC 28	TT FLAP GATE TRIPPED ON OLR	RESET DONE	14:20:00	14:30:00	
9	CHP	CC 201	TRIPPED ON OLR	RESET DONE	18:45:00	18:55:00	
10	CHP	CC 203	TRIPPED ON OLR	RESET DONE	14:35:00	14:45:00	
11	WT	OT 3	DRIVE 1 TRIPPED ON ENCODER FAULT	RESET DONE	16:30:00	16:30:00	