



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/06/2026

Area: OHP

Equipment	Job
spare mechanical BRS	1 no. panel preparation is done.
brc-4 on co-8a	Lubrication Pump cable got cut in festoon, rejoin done.
tbs-3 on co-21	LBC and RBC lighting is improved.
co-50,53,56 H/E hoists	ppm is done.
co-11 level	lighting is improved.
co-58,50,51 belt and carriage,53,56,57 ; wf-2,3,4,5	motor and panel side ppm is done.
co-38B	Field devices control cable tray along the conveyor was welded back in place properly.
om-16, 1-41lc3, lc-7 io racks	ppm is done, om-16, 1-141lc4 ground floor housekeeping is done.
TBS-7 on co-19 LT M1	motor base found broken, replaced with spare, thruster brake also replaced and trail run is taken.
CO-23 BRS	sensors alignment, cleaning was done and restored in circuit.