वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 19/10/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 21 lt	PCRD O/T acted due to Guide Problem	informed to Mech	22:30:00	23:00:00	
2	OHP	CO 34	OLR acted	Reset	23:50:00	00:00:00	
3	OHP	BRC on CO 31 B/C	OLR acted	Reset	00:35:00 02:00:00	00:50:00 02:10:00	
4	OHP	CO 29	OLR acted	Reset	03:10:00	03:20:00	
5	OHP	CO 25	olr acted	Reset	03:35:00	03:45:00	
6	OHP	BRC on CO 31 CT	Chain Broken	Informed to mech	03:45:00	04:00:00	
7	CHP	CC 37 ZSS	Belt slipping	Informed to OPRN	01:40:00	01:50:00	
8	CHP	CC 201	OLR acted	Reset	22:20:00	22:30:00	
9	CHP	CC 9	OLR acted	Reset	00:10:00	00:20:00	