



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/08/2026

Area: WT

Equipment	Job
OP 5	D2 motor replaced with spare due to shaft axial play
OT 3 series	Motor side ppm done