



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/08/2026

Shift: A

Incharge(s): P Venkat Kiran,P Venkat Kiran

| Sl No | Area | Equipment       | Problem                                             | Action                                                          | From     | To       | Remarks                         |
|-------|------|-----------------|-----------------------------------------------------|-----------------------------------------------------------------|----------|----------|---------------------------------|
| 1     | OHP  | brc-4 on co-8a  | all drives are not working                          | acb is in OFF condition. made on and trail run of BRC is taken. | 09:40:00 | 09:55:00 |                                 |
| 2     | OHP  | wobr-2 on co-29 | slew not working                                    | wrong complaint                                                 | 12:30:00 | 12:40:00 |                                 |
| 3     | OHP  | brc-5 on co-32  | Pump is not starting                                | control mcb was in trip condiition.                             | 11:00:00 | 11:10:00 | made on and trail run taken,.   |
| 4     | OHP  | co-8            | Rphase cable side lug got melted, relugging is done | trail run is taken and observed balance currents.               | 06:00:00 | 07:15:00 |                                 |
| 5     | CHP  | cc-131          | olr acted                                           | reset done                                                      | 09:15:00 | 09:20:00 |                                 |
| 6     | CHP  | cc-33 scr-2     | lt not taking place                                 | pcrd drum sensor acted. reset done                              | 07:10:00 | 07:20:00 |                                 |
| 7     | CHP  | scr-9 on cc-104 | slew not working                                    | slew pump air blast cooler trip. reset done and slew done.      | 10:10:00 | 10:20:00 |                                 |
| 8     | WT   | co-3            | tripped on olr                                      | reset done.                                                     | 07:30:00 | 07:35:00 | while jamming is being cleared. |