



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/07/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	08:25:00	08:30:00	
2	OHP	TT-2 C/S	REPORTED C/S NOT HEALTHY	SENSOR CLEANED THAN OK	11:40:00	11:50:00	
3	OHP	TBS ON CO-20	REPORTED NO POWER FOUND ACB AND MAIN CONTROL TRIP	ACB AND MAIN CONTROL ON THAN OK	07:40:00	08:00:00	
4	OHP	TBS ON CO-7A	REPORTED ALL DRIVES NOT WORKING FOUND ACB TRIP	ACB MADE ON	11:55:00	12:10:00	
5	OHP	CO-2A ,CO-5A	REPORTED NOT HEALTHY LBSS-1 I/C-2 TRIP	POWER RE-STORED THAN OK	07:30:00	08:00:00	
6	CHP	CC-7 C/S	NOT HEALTHY FOUND WIRE OPEN IN JB	WIRE RE-CONNECTED THAN OK	09:15:00	09:25:00	
7	CHP	CC-33 SCR-2	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED THAN OK	06:25:00	06:45:00	
8	CHP	CC-33 SCR-2	LT NOT WORKING E/STOP OPERATED	RELEASED THAN OK	07:15:00	07:35:00	
9	CHP	SCR-2	B/C NOT RUNNING SIGNAL MISSING	LT FORWARD THAN OK	09:25:00	09:45:00	
10	CHP	CC-131	OLR ACTED	RESET DONE	13:15:00	13:25:00	