



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/04/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC 26	OLR ACTED	RESET	03:45:00	04:50:00	4 TIMES
2	OHP	WBR ON CO 6A	BREAKER TRIPPED	MADE IT ON	05:35:00	05:45:00	
3	OHP	TBS ON CO 5A	B/C FLUID COUPLING OIL LOW	INFORMED TO MECH	02:30:00	02:45:00	
4	CHP	CC 58	OLR ACTED	RESET	05:30:00	05:45:00	
5	CHP	CC 51A RED	P/C ACTED	RELEASED	22:35:00	22:45:00	
6	CHP	CC 203	OLR ACTED	RESET	22:25:00	22:35:00	
7	CHP	SCR 5 ON CC 33 LT	DRIVE TRIP	RESET	23:05:00	23:15:00	
8	CHP	SCR 6 ON CC 106	POWER TRIPPED IN LC 2	MADE IT ON	03:25:00	03:40:00	
9	CHP	CC 107	OLR ACTED	RESET	03:40:00	03:45:00	