



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/05/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-67	Reported tripped	OLR acted.Reset done	18:30:00	18:40:00	
2	OHP	CO-26	OLR acted	OLR acted.Reset done	21:40:00	21:50:00	
3	CHP	CC-51	MPD tripped	Reset done	20:00:00	20:05:00	
4	CHP	Cc-132	PC acted	Released and tested okay	15:15:00	15:30:00	
5	IOSA	FLS WOBR	LT not taking place	Luffing down limit acted.Luff up done and LT tested okay	15:10:00	15:20:00	