



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/07/2026

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment     | Problem                                                      | Action                        | From                 | To                   | Remarks |
|-------|------|---------------|--------------------------------------------------------------|-------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO 26         | TRIPPED ON OLR                                               | RESET DONE                    | 07:35:00<br>10:35:00 | 07:45:00<br>10:40:00 |         |
| 2     | OHP  | TT 2 ON CO 15 | LT NOT TAKING PLACE/MPCB OUTGOING B PHASE GOT LOOSE          | B PHASE WIRE TIGHTEND THEN OK | 07:30:00             | 08:00:00             |         |
| 3     | CHP  | SCR 3 ON CC37 | DRIVE TRIPPED ON OLR                                         | RESET DONE                    | 07:25:00             | 07:30:00             |         |
| 4     | WT   | OT 3          | F/ R NOT TAKING PLACE/ DRIVE 2 TRIPPED ON EN CODER FAULT -43 | RESET DONE                    | 11:10:00             | 11:20:00             |         |