



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/06/2026

Area: CHP

Equipment	Job
CC 12/13 Gallery	12 nos LED fixtures replaced and improved lighting. Defective fixture removed
CC 55	New MD unit installed ,control cables laid up to LC 19 IO rack (I 17.6)kept in ckt and tested
SCR 8	CONTROL CABLE TAPING DONE
SCR 8 ON CC 112	PCRD MOTOR DISCONNECTED AND SENT TO ERS
CC 107, CC 108, CC 111 , CC 213 S-3	PPM DONE