



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/06/2026

Incharge(s): G Eswara Rao

Shift: A

| Sl No | Area | Equipment      | Problem                                                      | Action             | From                 | To                   | Remarks                       |
|-------|------|----------------|--------------------------------------------------------------|--------------------|----------------------|----------------------|-------------------------------|
| 1     | OHP  | CO 84          | ELECTRICAL BRS MALFUNCTIONING/2TIMES                         | BYPASSED AT MODULE | 07:00:00             | 07:30:00             | NO DELAY/TO BE KEPT IN CKT    |
| 2     | OHP  | CO 26          | TRIPPED ON OLR 3TIMES                                        | RESET DONE         | 07:05:00<br>08:50:00 | 07:10:00<br>08:55:00 |                               |
| 3     | OHP  | BRC 2 ON CO 30 | BC CJD WAS BYPASSED IN C SHIFT                               | CJD KEPT IN CKT    | 06:40:00             | 07:00:00             | NO DELAY                      |
| 4     | CHP  | CC 29          | ZSS ACTING/CAGE STUCKUP WITH MATERIAL                        | ZSS CAGE MADE FREE | 07:30:00             | 07:40:00             |                               |
| 5     | CHP  | CC 54          | TRIPPED ON OLR                                               | RESET DONE         | 12:35:00             | 12:45:00             |                               |
| 6     | CHP  | SCR 1 ON CC 31 | BOOM LUFFING UP and DOWN TRIPPING FREQUENTLY IN DOWN CUTTING | RESET DONE         | 06:45:00<br>12:45:00 | 07:00:00<br>13:15:00 | TO BE CHECKED MECH and ELECT. |