



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/06/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TIS-3	Reported tripped	Belt OLR acted.Reset done	21:50:00	22:00:00	
2	CHP	CC-54	MPD tripped	OLR acted.Reset done	21:20:00	21:25:00	
3	CHP	Cc-117	ZSS acted	Belt problem.	17:50:00	18:00:00	Informed to mechanical
4	CHP	LC-15	ALL conveyors red	Checked and found cable to OJH-4A got burnt.Breaker racked for construction power and I/C made on and given clearance	15:20:00	15:40:00	
5	CHP	SCR-8 on CO-112	Reported no operations taking place	Checked and found cable got damaged due to dumping to cleaning material.Cable identified and cores joint done.Operations tested okay	18:00:00	21:45:00	
6	CHP	CC-107	ZSS acted	Belt running slow due to over material	17:50:00	18:10:00	INformed to operation
7	CHP	CC-38 SCR-5	Lt not taking place	Drive tripped.Reset done	18:50:00 21:30:00	19:00:00 21:40:00	
8	CHP	CC-125	Reported tripped	OLR acted.Reset done	21:50:00	22:00:00	