



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/07/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS-21	CJD bypass	CJD, RMU terminations tightened and restored CJD in circuit. TBS Boom run signal Latch has been programmed and indication provided in OCR HMI	22:30:00	23:30:00	