



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/09/2026

Area: WT

Equipment	Job
CP 4 jobs	# Roof and side walls sheets welding done #power collector pads fixing and termination done # control wiring @ panel done # power charged # parameters ,auto tuning and motor direction testing done
OP 1	section isolators maintenance done 3nos (col no 91,87,81)