



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/09/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	OLR acted	Reset	03:00:00	03:15:00	
2	OHP	CO 25	OLR acted	Reset	22:50:00	23:00:00	
3	OHP	WBR on CO 6a	Slew Stop PB got stuck	Made it free	01:30:00	01:40:00	
4	OHP	BF 3a	ZSS Module problem	Bypassed in I/O rack	01:20:00	01:40:00	
5	CHP	CC 52	Feeding Conv OLR acted	Reset	04:45:00	04:50:00	