



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/08/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 8a	ACB is in off condition	Made it on	16:40:00	16:55:00	
2	OHP	WBR on CO 29 lt	M3 trip	Made it on	20:15:00	20:30:00	
3	OHP	CO 25	OLR acted	Reset	20:55:00	21:05:00	
4	CHP	CC 32 ZSS	Probe damaged	Replaced	17:10:00	17:30:00	
5	CHP	SCR 3 on CC 37	B/c Discharge chute probe got wet	Bypassed and informed to oprn	17:20:00	17:35:00	
6	CHP	CC 22	C/S probe cable insulation damaged	Properly insulated	19:10:00	19:20:00	
7	CHP	CC 103 T/T	Cable got cut	Rejoined	15:00:00	16:00:00	
8	WT	OP 8	Breaker tripped	Made it on	18:30:00	18:45:00	