



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/07/2026

Shift: A

Incharge(s): P Venkat Kiran,P Venkat Kiran

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR	RESET DONE	06:00:00	06:05:00	
2	OHP	BRC ON CO 28	BC TRIPPED ON OLR	RESET DONE	07:10:00	07:25:00	
3	OHP	CO 33M	TRIPPED ON OLR	RESET DONE	07:09:00	09:45:00	
4	OHP	TBS ON CO 20	LT NOT TAKING PLACE/PCRD TENSION ACTED	CABLE TENSION RELEASED	10:00:00	10:20:00	
5	OHP	TBS ON CO5A	LBC ZSS ACTED/CAGE STUCKUP WITH STONE	CAGE MADE FREE	12:30:00	12:45:00	
6	OHP	TBS ON CO 5A	ZSS ACTING/PROBE GOT DAMAGED	ZSS PROBE REPLACED	13:25:00 13:30:00	13:45:00 13:50:00	
7	CHP	S1 ON CC 36	LT NOT TAKING PLACE/PCRD TENSION ACTED	RESET DONE	06:40:00	06:50:00	