



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28 B/W 2	CHAIN SLIP	INFORMED TO MECH	22:40:00	22:55:00	
2	OHP	CO 26	OLR ACTED	RESET	01:40:00	01:50:00	
3	OHP	TIS 2	BELT MOTOR MPCB TRIP	MADE IT ON	00:25:00	00:30:00	
4	OHP	CO 12	OLR ACTED	RESET	00:40:00	00:45:00	
5	OHP	VF 2A	MPCB ACTED	RESET	03:55:00	04:05:00	
6	CHP	CC 125	OLR ACTED	RESET	03:15:00	03:20:00	
7	CHP	CC 51A	OLR ACTED	RESET	02:10:00	02:15:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	04:35:00	05:20:00	2 TIMES
9	CHP	CC 52	FEEDING CONV OLR ACTED	RESET	04:40:00	06:00:00	3 TIMES