



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/10/2026

Area: WT

Equipment	Job
CC 2	Area lighting, 1 no MCB and 1 no 200 W LED replaced
OT 3	D1, spare vacon drive replaced and testing done
OP 10	control wiring simplification job is going on ,removed external wires @TB for all drives
OP 9	2 nos cleats welding done in B phase @col no 89