



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/08/2026

Incharge(s): Saurabh Kumar Yadav, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	olr acted	reset	00:35:00	00:40:00	2 times
2	OHP	co 29	olr acted	reset	01:30:00	01:40:00	
3	OHP	wobr on CO 6A	B/W not working, CP-2 acted	reset	05:10:00	05:20:00	
4	OHP	co 26	olr acted	reset	05:15:00	05:25:00	
5	OHP	TBS on CO 19	no power, MCCB off	made it on	04:40:00	04:55:00	
6	CHP	CC 131	MPD ACTED	RESET	22:15:00	22:20:00	
7	CHP	CC 54	olr acted	reset	23:15:00	23:20:00	3 times
8	CHP	CC 55	olr acted	reset	05:15:00	05:20:00	
9	CHP	scr 2on CC 33	b/w not running, olr acted	reset	00:12:00	00:25:00	