



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/09/2026

Area: CHP

Equipment	Job
All LCs and CMs	De watering inspected
CC 43/44 Tunnel	Lighting ckt problem,damaged MCB replaced and improved lighting
SCR 1	ZSS,C/S,TUL ckt problem rectified
CC 29	Stop PB and chute sensor kept in ckt
CC 51 T/E	De watering pump provided and de watered
SCR 5 on CC 32	HT cable jointed by DNW,termination done and charged power