



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/07/2026

Shift: A

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment     | Problem                                                                 | Action                              | From     | To       | Remarks             |
|-------|------|---------------|-------------------------------------------------------------------------|-------------------------------------|----------|----------|---------------------|
| 1     | OHP  | CO 7          | BRS ACTED/JOD                                                           | RESET DONE                          | 11:45:00 | 12:00:00 |                     |
| 2     | OHP  | CO 3A         | PC ACTED/CABLE CUT DUE TO BABCAT WORKING TO CLEAR THE SPILLAGE MATERIAL | BYPASSED AT CJB                     | 12:35:00 | 12:50:00 | KEPT IN CKT 12.45PM |
| 3     | OHP  | CO 26         | TRIPPED ON OLR                                                          | RESET DONE                          | 07:30:00 | 07:40:00 |                     |
| 4     | OHP  | CO 33M        | TRIPPED ON OLR                                                          | RESET DONE                          | 07:55:00 | 08:00:00 |                     |
| 5     | OHP  | CO 58         | ZSS ACTED/CAGE STUCKUP WITH STONE                                       | CCAGE MADE FREE                     | 11:00:00 | 11:15:00 |                     |
| 6     | OHP  | CC 201        | TRIPPED ON OLR                                                          | RESET DONE                          | 08:40:00 | 08:50:00 |                     |
| 7     | OHP  | CO 59         | ZSS ACTED/CAGE STUCKUP                                                  | CAGE MADE FREE                      | 13:30:00 | 13:45:00 |                     |
| 8     | CHP  | CC 51         | MPD TRIPPED NO OLR                                                      | RESET DONE/2TIMES                   | 09:00:00 | 09:30:00 |                     |
| 9     | CHP  | CC 131        | TRIPPED ON OLR                                                          | RESET DONE                          | 10:00:00 | 10:10:00 |                     |
| 10    | CHP  | CC 58         | TRIPPED ON OLR                                                          | RESET DONE                          | 11:35:00 | 11:40:00 |                     |
| 11    | CHP  | SCR 3 ON CC37 | BC NOT RUNNING/MPR TRIPPED ON SP FAULT                                  | DIDNT FOUND ANY PROBLEM /RESET DONE | 11:05:00 | 11:15:00 |                     |
| 12    | CHP  | SCR 3 ON CC37 | BC NOT RUNNING/OLR ACTED                                                | RESET DONE                          | 12:00:00 | 12:10:00 |                     |
| 13    | WT   | OP 3          | F/R NOT TAKING PLACE /M1 POWER CABLE GOT DAMAGED                        | / RE JOINT DONE THEN OK             | 09:15:00 | 09:30:00 |                     |