



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment    | Problem                                      | Action                                                      | From                 | To                   | Remarks |
|-------|------|--------------|----------------------------------------------|-------------------------------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO-25        | OLR ACTED (2TIMES)                           | RESET DONE                                                  | 01:30:00<br>02:20:00 | 01:35:00<br>02:25:00 |         |
| 2     | OHP  | BRC on CO 8A | b/w not running,CP1 acted/mechanical problem | informed mechanical                                         | 05:10:00             | 05:20:00             |         |
| 3     | CHP  | CC-131       | OLR ACTED (2TIMES)                           | RESET DONE                                                  | 00:20:00<br>03:05:00 | 00:25:00<br>03:10:00 |         |
| 4     | CHP  | cc 52        | MPD acted                                    | reset                                                       | 01:40:00             | 01:45:00             |         |
| 5     | IOSA | OLD WOBR     | LT not working,OT acted                      | OT released,PCRD loop given,PCRD in OFF ,m/c @head end area | 22:30:00             | 22:40:00             |         |