



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/06/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	12:15:00	12:25:00	
2	OHP	BRC ON CO 32 LT	PCRD O/T ACTED	RELEASED	10:55:00	11:10:00	
3	OHP	TBS ON CO 20 LT	BREAK RESISTANCE COIL DAMAGED	REPLACED	11:50:00	12:30:00	
4	CHP	SCR 8 ON CC 112	TUL C/S MODULE PROBLEM	REPLACED	11:20:00	11:40:00	
5	CHP	CC 125	OLR ACTED	RESET	13:00:00	13:05:00	
6	CHP	CC 43	OLR ACTED	RESET	13:25:00	13:30:00	
7	CHP	CC 131	OLR ACTED	RESET	10:55:00	11:00:00	
8	CHP	CC 54	OLR ACTED	RESET	13:35:00	13:40:00	
9	WT	OT1	SOMETIMES NOT RUNNING	ALL CONNECTIONS TIGHTENED	08:30:00 11:30:00	09:30:00 13:00:00	
10	WT	OT3	D2 TRIP	RESET	10:00:00	10:05:00	
11	WT	OT4	D2 TRIP	RESET	13:55:00	14:00:00	