



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 29	olr acted	reset done	16:50:00	16:55:00	
2	OHP	wobr on co 25	boom conveyor not running	mechanical problem	16:50:00	17:00:00	
3	CHP	CC 29	zss acted,return wire loose connection	tightened	18:00:00	18:10:00	
4	CHP	CC 104 SCR4	LT not working,track jamming	informed operation	16:20:00	16:30:00	
5	CHP	CC 40 scr 7	Luff not working,mpr tripped	olr acted	18:40:00	18:45:00	
6	CHP	CC 51	mpd tripped	reset	20:00:00	20:05:00	3 times
7	CHP	CC 54	tripped on OLR	reset done	15:25:00	15:30:00	2 times