



वी.एस.पी  
VSP

RASHTRIYA ISPAT NIGAM LIMITED  
VISAKHAPATNAM STEEL PLANT  
RAW MATERIAL HANDLING PLANT  
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/10/2026

Area: CHP

| Equipment          | Job                                                                        |
|--------------------|----------------------------------------------------------------------------|
| CC 18,55,56,57,58  | PPM was done                                                               |
| CC 22              | ZSS cable replaced and kept in ckt                                         |
| LC 14 mast         | Kept in auto mode,out going connectors replaced                            |
| SCR 2              | Instrumentation sensors maintenance done                                   |
| SCR 4              | New modem configured and fixed                                             |
| LC 2 cellar        | Burnt submersible pump removed and new pump placed and de watering started |
| CC 47/48 gallery   | 6 nos 30W LED lamps provided                                               |
| JH C 209           | Sump pump trail run taken after mechanical job                             |
| CC 36,112,S1,SCR 8 | PPM was done                                                               |