



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/09/2026

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment     | Problem                  | Action                                                                                                           | From                 | To                   | Remarks  |
|-------|------|---------------|--------------------------|------------------------------------------------------------------------------------------------------------------|----------------------|----------------------|----------|
| 1     | OHP  | WOBR on CO-25 | Reported B/C not running | Checked and found control tripped due to luff down limit acted. Control made on and luff up done and tested okay | 20:00:00             | 20:20:00             |          |
| 2     | OHP  | CO-25         | Reported tripped         | OLR acted. Reset done                                                                                            | 21:00:00             | 21:05:00             |          |
| 3     | CHP  | Cc-58         | Reported tripped         | Tripped on current sp fault. Reset done                                                                          | 15:30:00<br>18:30:00 | 15:45:00<br>18:45:00 |          |
| 4     | CHP  | Cc-18         | Reported failed to start | Checked and found control voltage dropping when command given. PC bypassed and checked and tested okay           | 14:40:00             | 15:30:00             |          |
| 5     | CHP  | CC-19         | Reported tripped         | Failed to start. PC bypassed and tested okay                                                                     | 18:50:00             | 19:05:00             | no delay |
| 6     | CHP  | CC-28 FG      | Reported tripped         | OLR acted. Reset done                                                                                            | 21:30:00             | 21:35:00             |          |