



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 08/09/2026

Area: CHP

Equipment	Job
SCR 10	Instrumentation sensors maintenance was done
SCR 6	Running inspection defect rectified
CC 202	New BRS unit installed,wiring pending
CM 18	PLC panel painting done
S 1	PCRD motor power cable lug crimped,resistance contactor replaced
Transfer car	Power cable joints inspected and taping done
CM 27	Rooms cleaning done
Transfer car,CC 38,SCR 6	PPM was done
CC 51,51A	PPM was done