



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/05/2026

Area: WT

Equipment	Job
CO 3 (B/D)	Motor replaced due to burnt and tested
CP 2	Trolley line inspection done
OP 2	Panel and Motor side ppm done
OP 2	Roof painting done